

Non-tech fail

Water "control" fail

Ctrl valve 1 fail

Ext.temp < 0C

Partially/wholly closed

PIV
closed/obstructed

Alarm / check
valve fail

Too little H2O to sprinkler
system

Pipe failure (not
defined)

Obstruction
between sprinkler
& fire